



SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS

Paavo Ogren, Director

County Government Center, Room 207 • San Luis Obispo CA 93408 • (805) 781-5252
Fax (805) 781-1229 email address: pwd@co.slo.ca.us

July 12, 2013

**FAX AND EMAIL &
ATTACH TO CONTRACT**

**ADDENDUM NO. 2 TO
SEE CANYON ROAD SLIP OUT REPAIR
AVILA BEACH, CA
CONTRACT NO. 245R12B565**

**The final day, time and location for submittal of bid proposal remain unchanged:
Date / Time: Thursday, July 18, 2013 at 3:00 p.m.**

At: Office of the County Clerk
1055 Monterey Street, Room D-120
San Luis Obispo, California 93408

Certain revisions are hereby incorporated into the Contract Documents for the subject project. These revisions are as follows:

The section titled "SECTION 10.1 CONSTRUCTION DETAILS" is hereby amended as follows:

- 1) Section 10-1.30, "TERMINAL SYSTEMS (TYPE SKT and SRT)," add a new paragraph immediately after the first paragraph in this section on page 10-53 with the following:

Both Terminal Systems Guard Railing (Type SKT and SRT) shall be attached to the Concrete Barrier (Type 732, Modified) atop the proposed soldier pile wall by means of Connection Detail BB as shown on Caltrans Standard Plan A77J1.

The Project Plans are hereby amended as follows:

- 2) Replace the call-out identifying the Type SRT Terminal System on page 2 of 9 with the following:

METAL BEAM RAILING TERMINAL SYSTEM (TYPE SRT) PER CALTRANS STD. PLAN A77L1 & METAL BEAM GUARD RAILING CONNECTIONS TO CONCRETE BARRIER (TYPE 732, MODIFIED) PER A77J1.

- 3) Replace the call-out identifying the Type SKT Terminal System on page 2 of 9 with the following:

37.5 L.F. METAL BEAM RAILING TERMINAL SYSTEM (TYPE SKT) PER CALTRANS STD. PLAN A77L2 & METAL BEAM GUARD RAILING CONNECTIONS TO CONCRETE BARRIER (TYPE 732, MODIFIED) PER A77J1.

4) Delete the "NARROW ROADWAY MBGR POST INSTALLATION PER STD. PLAN A77C3" call-out on page 2 of 9.

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX TO US, TODAY, A SIGNED COPY OF THIS SHEET INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM (FAX (805) 781-1229).** If you are unable to read the fax, please call Jeff Werst in the Public Works Department at (805) 781-5252.



DF
PAAVO OGREN
Director of Public Works

File: Contract No. 245R12B565

ACKNOWLEDGMENT

Company Name

Printed Name

Signature

Date

L:\DESIGN\JUL13\245R12B565 Addendum No. 2.doc.jwerst.taw