SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS
Paavo Ogren, Director

County Government Center, Room 207 • San Luis Obispo CA 93408 • (805) 781-5252
Fax (805) 781-1229 email address: pwd@co.slo.ca.us

July 2, 2013

SEE CANYON ROAD SLIP OUT REPAIR
AVILA BEACH, CA
CONTRACT NO. 245R12B565
BIDDER'S INQUIRIES

This memo is to inform the Contractors listed on the planholder's list that the response to bidder's inquires have been posted to the website at

http://www.slocounty.ca.gov/PW/Design_Division/Projects_Out_To_Bid.htm.

For those Contractor's that do not have access to internet, attached is the response.

The response to bidder's inquires, unless incorporated into a formal addendum to the contract, are not a part of the contract and are provided for the bidder's convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The availability or use of information provided in the responses to bidder's inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03 of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications or Special Provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary from a response previously given.

To submit a "Request For Information (RFI)", please fill out the form located on the San Luis Obispo County's Public Work's website at

http://www.slocounty.ca.gov/PW/Design_Division/Projects_Out_To_Bid/Bidder_Request_For_Information_-_PCR.htm.

Please contact me with any questions at (805) 781-4480.

Sincerely,

JEFF WERST, PE
Design Division Manager

Enclosures: Answers to Bidder Questions last updated July 2, 2013 (1 page)

c: Don Spagnolo

File: Contract No. 245R12B565

L:\DESIGN\JUL13\245R12B565 RFI No. 1.doc.jwerst.taw

See Canyon Road Slope Repair Project, Avila Beach, CA

CONTRACT 245R12B565

ANSWERS TO BIDDER QUESTIONS

LAST UPDATED: 2 July 2013

NOTICE: The Contract Documents govern. Responses are for information only and are not part of the Contract Documents.

SECTION	PAGE	DWG	RESPONSE DATE	QUESTION[1]	ANSWER
10-1.01 & Project Plans	10-1	3 of 9	7-Jul-13	Bid item number two (2). "Temporary Fence (Type ESA)" shows that there is 100 LF. Plan sheet three (3), shows that there is approximately 270 LF. Can you please clarify which quantity is correct?	The total ESA fencing required for the project is approximately 100 lf. This will be addressed in an upcoming addendum.

[1] The COUNTY rephrases questions for clarity and consistency.