



SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS

Paavo Ogren, Director

County Government Center, Room 207 • San Luis Obispo CA 93408 • (805) 781-5252

Fax (805) 781-1229

email address: pwd@co.slo.ca.us

May 13, 2013

**FAX ONLY &
ATTACH TO CONTRACT**

**ADDENDUM NO. 1 TO
WATER DISTRIBUTION SYSTEM UPGRADES
COUNTY SERVICE AREA 10A
CAYUCOS, CA
CONTRACT NO. 300383**

**The final day, time and location for submittal of Bid remain unchanged:
Date / Time: Thursday, May 23, 2013 at 3:00 p.m.**

At: Office of the County Clerk
1055 Monterey Street, Room D-120
San Luis Obispo, California 93408

Certain revisions are hereby incorporated into the Bidding Documents for the subject project. These revisions are as follows:

Appendix A – Specifications, Section 1. General Requirements is hereby amended as follows:

- 1) Insert the following at the end of Paragraph 1.12 “Payments” at the bottom of page 1-14:

C. Contractor Certification

The Contractor will be required to certify each progress pay estimate. The certification will include the following Contractor Verification: Contractor has carefully reviewed this entire document and hereby attests that the quantities and amounts stated herein accurately represent the total Work that has been performed, and materials that have been provided, under this Contract, and that all such Work and materials are in compliance with the Contract Documents.

Appendix A – Specifications, Section 2. Technical Specifications, is hereby amended as follows:

- 1) Under Paragraph 2.30 “Plastic Watermain Pipe,” delete the third paragraph at the top of page 2-38 in its entirety and replace with the following:

Any curving of the pipe through bending to avoid obstructions shall be in strict compliance with the manufacturer's recommendations, and the Contractor shall ensure that angular deflections at the pipe joints do not exceed the manufacturer's limits. At minor changes in alignment or grade where the pipe cannot be deflected, the Contractor shall install a coupling that allows for minor (five degrees or less) deflections in accordance with the pipe manufacturer's recommendations. An acceptable high deflection coupling for this application shall be "Fluid-Tite PVC Stop & Repair Coupling" by CertainTeed, or approved equal. Usage and installation of such couplings shall be in conformance with the manufacturer's recommendations. The Contractor shall coordinate review and approval by the Engineer of each proposed installation location prior to construction. If the manufacturer's recommended coupling cannot provide adequate deflection, the Contractor shall install a ductile iron fitting to allow for the changes in alignment or grade.

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX TO US, TODAY, A SIGNED COPY OF THIS SHEET INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM (FAX (805) 781-1229).** If you are unable to read the fax, please call Jeff Werst in the Public Works Department at (805) 781-5252.

DF


PAAVO OGREN
Director of Public Works

Enclosure:

File: Contract No. 300383

ACKNOWLEDGMENT

| _____ Company Name | _____ Printed Name | _____ Signature | _____ Date |
|-----------------------|-----------------------|--------------------|---------------|
|-----------------------|-----------------------|--------------------|---------------|

L:\DESIGN\MAY13\300383 CSA 10A Waterline Addendum 1.doc.jwerst.taw