



SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS

Paavo Ogren, Director

County Government Center, Room 207 • San Luis Obispo CA 93408 • (805) 781-5252

Fax (805) 781-1229

email address: pwd@co.slo.ca.us

May 20, 2013

**FAX ONLY &
ATTACH TO CONTRACT**

**ADDENDUM NO. 3 TO
WATER DISTRIBUTION SYSTEM UPGRADES
COUNTY SERVICE AREA 10A
CAYUCOS, CA
CONTRACT NO. 300383**

**The final day, time and location for submittal of Bid remain unchanged:
Date / Time: Thursday, May 23, 2013 at 3:00 p.m.**

At: Office of the County Clerk
1055 Monterey Street, Room D-120
San Luis Obispo, California 93408

Certain revisions are hereby incorporated into the Bidding Documents for the subject project. These revisions are as follows:

Appendix A – Specifications, Section 2. Technical Specifications, is hereby amended as follows:

- 1) Under Paragraph 2.58 "Hot Mix Asphalt Concrete Pavement," add the following to the end of the first paragraph of Paragraph 2.58 on page 2-56:

The pavement condition index (PCI) for the project roads is less than 65. In accordance with Table 1 of County Standard Drawing R-3a (included on sheet 14 of 15 of the Contract Drawings), the minimum lane width repair limits require only the 12" minimum T-section. Additional grinding beyond the T-section cut will not be required.

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX TO US, TODAY, A SIGNED COPY OF THIS SHEET INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM (FAX (805) 781-1229).** If you are unable to read the fax, please call Jeff Werst in the Public Works Department at (805) 781-5252.

DF

PAAVO OGREN
Director of Public Works

File: Contract No. 300383

ACKNOWLEDGMENT

Company Name

Printed Name

Signature

Date

L:\DESIGN\MAY13\CSA 10A Waterline Addendum 3.doc.rtf