



SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS

Paavo Ogren, Director

County Government Center, Room 206 • San Luis Obispo CA 93408 • (805) 781-5252
Fax (805) 781-1229 email address: pwd@co.slo.ca.us

May 15, 2014

**FAX AND EMAIL &
ATTACH TO CONTRACT**

**ADDENDUM NO. 2 TO
SIDEWALK IMPROVEMENTS FOR
CROCKER STREET
TEMPLETON, CA
CONTRACT NO. 300495**

**The final day, time and location for submittal of bid proposal remain unchanged:
Date / Time: Thursday, May 22, 2014 at 3:00 p.m.**

At: Office of the County Clerk
1055 Monterey Street, Room D-120
San Luis Obispo, California 93408

Certain revisions are hereby incorporated into the Contract Documents for the subject project. These revisions are as follows:

The section titled "BID PROPOSAL AND FORMS" is hereby amended as follows:

- 1) Replace the "BID PROPOSAL" Page A-8(a) attached to Addendum No. 1 with the Bid Proposal attached to this addendum. Attention is directed to the estimated quantity for Bid Item No. 6.

The section titled "CONSTRUCTION DETAILS" is hereby amended as follows:

- 2) Replace the first paragraph below 10-1.19 "Curb Ramp Detectable Warning System:" on page 10-36 with the following:

"Truncated Dome Mats shall be placed in accordance with the 2006 Caltrans Standard Plan A88A and these special provisions. Truncated Dome Mats shall be placed as shown on the Plans and as directed by the Engineer, and shall be surface mounted mats with the following dimensions:

- 3) Below the first paragraph of 10-1.19 "Curb Ramp Detectable Warning System:" on page 10-36, delete the following:

Length: 12 feet
Width: 36 inches

The section titled "PLANS" is hereby amended as follows:

- 4) Remove the "6" Concrete" label shown in the proposed sidewalk offset from Sta. 10+80.0 on Sheet C3.
- 5) On Sheets C2 and C3 add the following sentence to Construction Note #6 and #7:
"Sawcut as shown or as directed by the Engineer. Repave per County Standard R-3, as directed by the Engineer. No T-Section required."

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX TO US, TODAY, A SIGNED COPY OF THIS SHEET INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM (FAX (805) 781-1229).** If you are unable to read the fax, please call Jeff Werst in the Public Works Department at (805) 781-5252.

DF


PAAVO OGREN
Director of Public Works

Attachment: Bid Proposal

File: Contract No. 300495

ACKNOWLEDGMENT

_____	_____	_____	_____
Company Name	Printed Name	Signature	Date

L:\DESIGN\MAY14\300495 Addendum No. 2.doc

**SIDEWALK IMPROVEMENTS
FOR CROCKER STREET
TEMPLETON, CA
CONTRACT NO. 300495
BID PROPOSAL**

ITEM NO.	CODE NO.	DESCRIPTION OF ITEM	ESTIMATED QUANTITY	UNIT	BID UNIT PRICE	BID PRICE
1	074016	CONSTRUCTION SITE MANAGEMENT	1	LS	LUMP SUM	
2	120090	CONSTRUCTION AREA SIGNS	1	LS	LUMP SUM	
3	120100	TRAFFIC CONTROL SYSTEM	1	LS	LUMP SUM	
4	150711	REMOVE PAINTED TRAFFIC STRIPE	74	LF		
5	150768	REMOVE ASPHALT CONCRETE PAVEMENT	445	SF		
6	152379	RELOCATE FENCE	50	LF		
7	152386	RESET SIGN	2	EA		
8	153140	REMOVE CONCRETE SIDEWALK	381	SF		
9	160101	CLEARING AND GRUBBING	1	LS	LUMP SUM	
10	190101	ROADWAY EXCAVATION	275	CY		
11	260201	CLASS 2 AGGREGATE BASE	59	CY		
12	300435	TRUNCATED DOME MAT	96	SF		
13	390132	HOT MIX ASPHALT (TYPE A)	5	TON		
14	394090	PLACE HOTMIX ASPHALT (MISCELLANEOUS AREAS)	30	SY		
15	731504	MINOR CONCRETE (CURB AND GUTTER)	56	LF		
16	731516	MINOR CONCRETE (DRIVEWAY)	4	CY		
17	731521	MINOR CONCRETE (SIDEWALK)	42	CY		
18	731623	MINOR CONCRETE (CURB RAMP)	2	CY		
19	839523	BARRIER (WOOD POST)	14	EA		
20	840656	PAINT TRAFFIC STRIPE (2-COAT)	81	LF		
TOTAL BID						

Bidder's Name: _____