



SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS

Wade Horton, Director

County Government Center, Room 207 • San Luis Obispo CA 93408 • (805) 781-5252

Fax (805) 781-1229

email address: pwd@co.slo.ca.us

December 18, 2014

**FAX AND EMAIL &
ATTACH TO CONTRACT**

**ADDENDUM NO. 3 TO
NACIMIENTO WATER PROJECT
NACIMIENTO RIVER CROSSING PIPE REPAIR
NORTHWEST OF PASO ROBLES, CA
CONTRACT NO. 300529**

**The final day, time and location for submittal of bid proposal remain unchanged:
Date / Time: Monday, December 22, 2014 at 3:00 p.m.**

At: Office of the County Clerk
1055 Monterey Street, Room D-120
San Luis Obispo, California 93408

Certain revisions are hereby incorporated into the Contract Documents for the subject project. These revisions are as follows:

The section titled "BID PROPOSAL AND FORMS" is hereby amended as follows:

- 1) On Page FC-16, "CERTIFICATION OF BIDDER'S EXPERIENCE," replace the first paragraph of the page in its entirety with the following:
"As indicated in paragraph 1-1.01 'HDPE Carrier Pipe Installation Experience' of Section 02312 'Installation of HDPE Carrier Pipe,' the carrier pipe installation shall be performed by a California-licensed contractor (Class A or C-34) that has extensive experience with installation of pipelines using horizontal directional drilling (HDD) construction methods and operation of specialized HDD equipment that are more fully described in Section 02312, and that the contractor's experience record indicating projects demonstrating the required experience shall be submitted with the bid. This form shall be completed, signed by bidder, and submitted with bidder's bid. If the HDPE carrier pipe installation is to be performed by a subcontractor, the form shall be completed and signed by the subcontractor, and submitted with the bidder's bid. Failure to complete, sign, and submit with bidder's bid may result in bidder's bid being rejected."
- 2) On Pages FC-16, FC-17, FC-18, and FC-19 on the bottom right hand side, please disregard the words "Bidder's Bond."

The section titled Section 10 "CONSTRUCTION DETAILS" is hereby amended as follows:

- 3) On Page 1 of Section 01500 "CONSTRUCTION FACILITIES AND TEMPORARY CONTROLS," to the end of paragraph 3 "Discharge of Construction Water," add the following:

"As shown on Sheet G-02 of the Drawings, construction water and dewatering water may be disposed of at the NWP Camp Roberts tank overflow basin, subject to approval of the Engineer. The Contractor shall be responsible to ensure that the water disposed of at the basin is free from contaminants, sediments and debris, to the satisfaction of the Engineer. Disposal of slurry, if used by the Contractor for installation of the HDPE carrier pipe, shall not be allowed at the basin."

- 4) On Page 2 of Section 02312 "INSTALLATION OF HDPE CARRIER PIPE," replace paragraph 1-2.02 "Cleaning the Steel Casing Pipe" in its entirety with the following:

1-2.02 Cleaning the Steel Casing Pipe

Due to the presence of holes in the existing steel casing pipe, the water level inside the existing casing pipe can be expected to fluctuate depending on the groundwater elevation, and the Contractor should plan his/her work accordingly. For the purposes of bidding, the Contractor shall assume that the level of water in the existing casing pipe will be approximately the same as the channel elevation of the Nacimiento River over the pipe, as shown in profile on Sheet C-01 of the Drawings. The Contractor shall clean the steel casing pipe by performing swabbing and mandrel testing by operating from the pulling rig. Sediment and debris inside the steel casing pipe shall be removed from the site and disposed of. Disposal of sediment and debris at the NWP Camp Roberts tank overflow basin shall not be allowed."

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX TO US, TODAY, A SIGNED COPY OF THIS SHEET INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM (FAX (805) 781-1229).** If you are unable to read the fax, please call Jeff Werst in the Public Works Department at (805) 781-5252.



WADE HORTON
Director of Public Works

File: Contract No. 300529

ACKNOWLEDGMENT

Company Name

Printed Name

Signature

Date

L:\DESIGN\DEC14\300529 Addendum No. 3.docx.jwerst.taw