



SAN LUIS OBISPO COUNTY
DEPARTMENT OF PUBLIC WORKS

Wade Horton, Director

County Government Center, Room 207 • San Luis Obispo CA 93408 • (805) 781-5252
Fax (805) 781-1229 email address: pwd@co.slo.ca.us

December 17, 2014

**FAX AND EMAIL &
ATTACH TO CONTRACT**

**ADDENDUM NO. 2 TO
NACIMIENTO WATER PROJECT
NACIMIENTO RIVER CROSSING PIPE REPAIR
NORTHWEST OF PASO ROBLES, CA
CONTRACT NO. 300529**

**The final day, time and location for submittal of bid proposal remain unchanged:
Date / Time: Monday, December 22, 2014 at 3:00 p.m.**


At: Office of the County Clerk
1055 Monterey Street, Room D-120
San Luis Obispo, California 93408

Certain revisions are hereby incorporated into the Contract Documents for the subject project. These revisions are as follows:

The section titled Section 10 "CONSTRUCTION DETAILS" is hereby amended as follows:

- 1) On Page 2 of Section 02312 "INSTALLATION OF HDPE CARRIER PIPE," replace paragraph 1-1.02 "Pulling Rig Capacity" in its entirety with the following:
"1-1.02. Pulling Rig Capacity. The pulling equipment used for the Work shall be of sufficient capacity to successfully complete the HDPE carrier pipe installation. The pulling rig equipment shall be capable of achieving a pullback capacity of 340,000 lbs, or 150% of the maximum anticipated HDPE carrier pipe pulling force required to perform the Work per Paragraph 1-5 'PULLBACK OPERATIONS – GENERAL REQUIREMENTS.'"

All bidders shall acknowledge acceptance of this correction notice. **PLEASE FAX TO US, TODAY, A SIGNED COPY OF THIS SHEET INDICATING CONFIRMATION OF RECEIPT OF THIS ADDENDUM (FAX (805) 781-1229).** If you are unable to read the fax, please call Jeff Werst in the Public Works Department at (805) 781-5252.


WADE HORTON
Director of Public Works

File: Contract No. 300529

ACKNOWLEDGMENT

Company Name	Printed Name	Signature	Date
--------------	--------------	-----------	------