

Technical Memorandum Name: Partially Mixed Facultative Pond, March 2008
Commenter: TAC Engineering Working Group
Comments Date: June 24, 2008
Responses Date: July 3, 2008

The following comments were submitted in response to the above listed Technical Memorandum (TM). The TM was developed as part of the EIR process for the project, in order to help facilitate and broaden the discussion of project issues important to the community. The responses should be considered preliminary because the EIR process is not complete, and the information necessary to fully respond has not yet been developed. The project team is grateful to those citizens who took the time to review the TM and provide comments at this early stage in the process. The project team will endeavor to fully address the comments and concerns through the on-going project development process.

	Comment	Response
1	The most distinct advantage of the facultative ponding system is the greatly reduce sludge production as compared to the other treatment options. As indicated in the Fine Screening report, sludge management can range up to 40% of the annual operations and maintenance costs for certain treatment/collection system combinations (Digested/Composted treatment of biosolids, gravity collection).	Comment noted.