

Condition 110	Midtown Pump Station
----------------------	-----------------------------


The aboveground facilities for the mid-town pump station shall be re-located to Palisades Avenue (south of the Library) on APN 074-229-017.

Evidence of compliance:


The only above-ground features of the Midtown pump station at the southwest corner of the Midtown site will be three electrical boxes (addressed in evidence of compliance for Condition 51).

The generator building for this pump stations will be constructed at the northeast corner of the Midtown parcel, just north of the South Bay Library (PS-C-204). The change in generator location from the Los Osos Community Park to the library site was approved by the Coastal Commission via immaterial amendment on March 8, 2012.

Condition Satisfied



Director, SLO County Planning



Date

CALIFORNIA COASTAL COMMISSION

CENTRAL COAST DISTRICT OFFICE
 725 FRONT STREET, SUITE 300
 SANTA CRUZ, CA 95060
 PHONE: (831) 427-4863
 FAX: (831) 427-4877
 WEB: WWW.COASTAL.CA.GOV

**COASTAL DEVELOPMENT PERMIT AMENDMENT**

Coastal Development Permit (CDP) Number: A-3-SLO-09-055 and A-3-SLO-09-069

Amendment Number: A-3-SLO-09-055/069-A1

Permittees: San Luis Obispo County

Amendment Issue Date: March 12, 2012

Original CDP Approval

CDP A-3-SLO-09-055/069 was originally approved by the Coastal Commission on June 11, 2010, and it authorized the construction and operation of a community sewer system (including a treatment plant, collection/disposal/reuse facilities, and all associated development and infrastructure) in the unincorporated coastal community of Los Osos adjacent to Morro Bay in central San Luis Obispo County (with the treatment plant located at 2198 Los Osos Valley Road and other related infrastructure located throughout Los Osos).

CDP Amendment

CDP A-3-SLO-09-055/069 is amended to allow the generator building associated with the Midtown pump station facility to be relocated from Los Osos Community Park to the parking lot area of the Los Osos branch of the San Luis Obispo County Library system.

Coastal Commission Concurrence

This amendment was determined by the Executive Director to be immaterial, was duly noticed, and no objections were received and/or the Commission concurred with the Executive Director's determination of immateriality. This amendment will become effective upon return of a signed copy of this form to the Central Coast District Office. Please note that the CDP terms and conditions, including as modified by this amendment and/or previous amendments if applicable, remain in effect.

Authorized by Madeline Cavalieri, Central Coast District Manager

Acknowledgment

I/We have read and understand the above and agree to be bound by the terms and conditions of CDP A-3-SLO-090-055 and A-3-SLO-09-069 as amended.

Signature of Permittee (San Luis Obispo County)

3/22/2012

Date




California Coastal Commission


©2012 CDM SMITH. ALL RIGHTS RESERVED. THESE DOCUMENTS AND DESIGNS PROVIDED BY PROFESSIONAL SERVICE, INCORPORATED HEREIN, ARE THE PROPERTY OF CDM SMITH AND ARE NOT TO BE USED, IN WHOLE OR PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CDM SMITH. REUSE OF DOCUMENTS: THESE DOCUMENTS ARE THE PROPERTY OF CDM SMITH AND ARE NOT TO BE USED, IN WHOLE OR PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CDM SMITH.

A B C D E F G H I J K L

- NOTES:
- LIDS AND VAULTS TO BE TRAFFIC RATED FOR H-20 LOADING.
 - COORDINATE ELECTRICAL DUCTBANK DEPTH AND LOCATION BEFORE INSTALLATION OF UTILITY PIPING. SEE SHEET PS-E-206.



STANDBY POWER & 5A POCKET PUMP STATION PLAN



REV. NO.	DATE	DRWN	CHKD	REMARKS

DESIGNED BY: MPH
 DRAWN BY: JAW
 CHECKED BY: CCA
 DATE: APRIL 2012

CDM Smith
 2295 Gateway Oaks Drive, Suite 240
 Sacramento, CA 95833
 Tel: (916) 567-9900



0 1/2 1
 IF THIS BAR DOES NOT MEASURE 1" THEN ADJUST SCALE ACCORDINGLY



DIGALERT
 DIAL TOLL FREE 1-800-642-2444
 AT LEAST TWO DAYS BEFORE YOU DIG
 UNDERGROUND SERVICE ALERT OF NORTHERN CALIFORNIA

LOS OSOS WASTEWATER COLLECTION SYSTEM
MID-TOWN STANDBY POWER SITE PLAN

PROJECT NO. 42502-83120
 FILE NAME: PS-C-204
 SHEET NO.
PS-C-204