


| | |
|--|------------------------|
| Condition 19 | Erosion Control |
| <p>Prior to commencement of grading activities for each facility, erosion control measures shall be incorporated into the grading plans to minimize the potential for erosion or loss of top soil during grading to the satisfaction of the Planning Director. Any erosion and sedimentation control netting or other erosion and sedimentation control devices used for temporary or permanent erosion and sedimentation control, shall be limited to biodegradable mesh or other biodegradable products.</p> | |
| <p>Evidence of compliance:</p> <p>The Los Osos Wastewater Project will require grading for the construction of the leach fields that will be located on the Broderson property and some minimal grading for the trenching, the nine (9) pump station and (13) pocket pump station sites associated with the collection system. In order to minimize the potential for erosion and loss of top soil during construction, a storm water pollution prevention plan (SWPPP) was prepared for the both the leach fields and the collection system. The SWPPPs outline erosion control measures required during construction and are part of the project specifications the contractor(s) will be required to adhere to.</p> <p>For condition compliance verification, attached are 11x17 copies of the leach field and collection system SWPPPs. A separate SWPPP will be prepared for the treatment plant, which will be located on the Giacomazzi property East of town.</p> | |

Condition Satisfied - Collection System


 Director, SLO County Planning

APRIL 3, 2017
 Date