

Condition 21	Erosion Control-Surface Waters
<p>Prior to commencement of grading activities for each facility, the plans shall provide for the control of surface water away from slopes to the satisfaction of the Planning Director in consultation with the Public Works Department.</p>	
<p>Evidence of compliance:</p> <p>Construction of the water recycling facility will require grading during construction of the recycled water storage ponds, associated buildings, access road and trenching for pipelines. In order to minimize the potential for erosion and loss of top soil during construction, graded slopes will be treated with erosion control measures per the storm water pollution prevention plan (SWPPP) that was prepared. The SWPPP was filed with the State Water Resources Control Board and the contractor will be required to adhere to provisions within the SWPPP.</p> <p>For condition compliance verification, attached is a copy of the Los Osos Water Recycling Facility Project – SWPPP Plan, prepared by a Certified Professional in Erosion and Sediment Control, shows the erosion control measures to be implemented during construction. The erosion control measures shown on the SWPPP will provide control of surface waters, protect slopes and minimize erosion during construction.</p>	

Treatment Plant Condition Satisfied



 Director, SLO County Planning

12/5/13

 Date