


<b>Condition 21</b>	<b>Erosion Control-Surface Waters</b>
<p>Prior to commencement of grading activities for each facility, the plans shall provide for the control of surface water away from slopes to the satisfaction of the Planning Director in consultation with the Public Works Department.</p>	
<p><b>Evidence of compliance:</b></p> <p>Construction of the collection system portion of the Los Osos Wastewater Project will require grading during construction of the leach fields that will be located on the Broderson property and some minimal grading for trenching, the nine (9) pump stations and their associated back up generator buildings. Graded slopes will be minimal to non-existent, however, in order to minimize the potential for erosion and loss of top soil during construction, a storm water pollution prevention plan (SWPPP) was prepared for both the leach fields and the collection system. The SWPPP was filed with the State Water Resources Control Board and the contractor will be required to adhere to provisions within the SWPPP.</p> <p>For condition compliance verification, attached are pertinent 11x17 copies of the SWPPP plan sheets showing the erosion control measures to be implemented during construction of the collection system portion of the LOWWP. The erosion control measures shown on the SWPPP will provide control of surface waters, protect slopes and minimize erosion during construction.</p> <p>For reference, and verification of condition compliance, <u>copies of plans prepared by a Certified Professional in Erosion and Sediment Control</u> are attached. Specifically the following sheets show information relative to erosion control:</p> <p>C-ED-331, SWPPP007, SWPPP008, SWPPP011 to 016, SWPPP017 and 018, SWPPP021 to 023, SWPPP025</p> <p><b>Note:</b> Because the wastewater treatment facility design has not been completed, evidence of compliance will be submitted under separate cover.</p>	

**Collection System Condition Satisfied**

  
 \_\_\_\_\_  
 Director, SLO County Planning

MAY 31 2012  
 \_\_\_\_\_  
 Date

**Treatment Plant Condition Satisfied**

\_\_\_\_\_  
 Director, SLO County Planning

\_\_\_\_\_  
 Date