

Condition 22	Seismic Requirements
All proposed facilities shall be designed and constructed in accordance with UBC Seismic Zone 4 regulations.	
<p>Evidence of compliance:</p> <p>All structures associated with the treatment facility will be designed to resist seismic and wind loads in accordance with the 2010 California Building Code and ASCE 7-05- minimum design loads. It should be noted that the Seismic Zone 4 regulations noted in Condition 22 are no longer in effect as the 1997 UBC that prescribed them is superseded by the 2010 CBC, which was used in the design of this project.</p> <p>For reference, and verification of condition compliance, attached are copies of final stamped and signed plans by the licensed engineer in charge of project seismic design.</p> <p>Specifically the following attached sheets show information relative to seismic design:</p> <p>Section 01612 - Seismic Design Criteria Specifications (Attachment 1) Drawing 00G10 - Structural General Notes (Attachment 2)</p>	

Condition Satisfied

Mary Ann

Director, SLO County Planning

12/4/13

Date