

Condition 42	Noise
<p>The County shall require that the treatment plant be designed so that the backup diesel generator is enclosed in a structure and is located a minimum of 250 feet away from the nearest residence.</p>	
<p>Evidence of compliance:</p> <p>Per Attachment 1, the nearest residence is more than 250 feet away from the treatment plant's backup diesel generator.</p> <p>The backup diesel generator is located in the electrical building on the east side of the Los Osos Water Recycling Facility (WRF) site.</p>	

Condition Satisfied



 Director, SLO County Planning

 5/29/13
 Date

