


Condition 47	Temporary Fire Flows
<p>To reduce the potential temporary loss of water for firefighting that may occur as a result of construction activities, the project shall compensate for the potential temporary loss of water through means determined by the County Fire Chief.</p>	
<p>Evidence of compliance: Please refer to the attached email correspondence with Cal Fire/County of SLO Fire Chiefs, Paul Lee and Robert Lewin, which provides concurrence with the means of compensating for the potential temporary loss of water. This will be achieved through staging a Water Tender at the South Bay Fire Department during construction, weekly coordination between the Construction Team and the Fire Department, and providing the Fire Department an overall project schedule.</p>	

Condition Satisfied



Director, SLO County Planning

APRIL 6, 2012

Date



Fw: Los Osos Wastewater Project - Fire Flows
Lee, Paul to: 'jwaddell@co.slo.ca.us'

03/29/2012 01:49 PM

History: This message has been replied to.

John

We are good. Thanks for the opportunity!

Paul Lee
Battalion Chief / Fire Marshal
805-543-4244

----- Original Message -----
From: Lewin, Robert
Sent: Wednesday, March 28, 2012 09:01 AM
To: Lee, Paul
Cc: Richardson, John; Veneris, Phil
Subject: Re: Los Osos Wastewater Project - Fire Flows

Yes I think moving the WT is in the works.
Thanks,

Robert Lewin, Fire Chief

Mobile Device

----- Original Message -----
From: Lee, Paul
Sent: Wednesday, March 28, 2012 08:43 AM
To: Lewin, Robert
Subject: FW: Los Osos Wastewater Project - Fire Flows

If you are happy I will let John know, Phil has had input prior to it reaching you.

Let me know

Paul Lee
Battalion Chief / Fire Marshal
CAL FIRE San Luis Obispo
635 N. Santa Rosa
San Luis Obispo, CA. 93405
805-543-4244 Office
805-543-4248 Fax

-----Original Message-----
From: jwaddell@co.slo.ca.us [mailto:jwaddell@co.slo.ca.us]
Sent: Wednesday, March 28, 2012 8:15 AM
To: Lee, Paul
Subject: Los Osos Wastewater Project - Fire Flows

Paul,

As you are aware, the County has a requirement in the Coastal permit

conditions to address the potential loss of firefighting water that may occur during the construction of the Los Osos Wastewater Project. The actual condition states the following.

"To reduce the potential temporary loss of water for firefighting that may occur as a result of construction activities, the project shall compensate for the potential temporary loss of water through means determined by the County Fire Chief."

The project does not include any plans to take existing water systems out of service. However, construction of underground sewer pipelines and other improvements do have the potential to result in unplanned breaks and service interruptions. The County will coordinate with the water purveyors in Los Osos to locate underground water pipelines and minimize potential service interruptions. In the event of an interruption, the County will coordinate with the affected water purveyor to notify the South Bay Fire Department and restore service as soon as possible.

Based on our recent discussions and the approach for the LOCS D project in 2005, it is our understanding that the South Bay Fire Department will house a Water Tender in Los Osos for the duration of the Project, which is approximately 2 years. Prior to construction, the County will provide the South Bay Fire Department with an overall construction schedule for planning purposes and keep their personnel informed, on a weekly basis, of the areas of Los Osos where construction is occurring and the Water Tender may need to be dispatched. All areas of the project site and work will be available for inspection by fire department personnel at any time.

Please let us know if this approach meets the expectations of the Fire Chief. Thank you for your assistance with this issue.

JOHN WADDELL
Project Engineer
County of San Luis Obispo
Department of Public Works
County Government Center, Room 207
San Luis Obispo, CA 93408
Office: (805) 788-2713
Cell: (805) 459-5034
Fax: (805) 781-1229

[Scanned @co.slo.ca.us]