

San Luis Obispo County, California

Above Ground Tank (AGT) Program Information

- All AGTs that contain petroleum products require secondary containment for each tank or group of tanks pursuant to Code of Federal Regulations (CFR) 40, §112.7 and HSC §25270.4.5(b)(3)
- Secondary containment shall contain the entire contents of the largest tank plus 10%
- A Spill Prevention Control and Countermeasure (SPCC) Plan is required for tanks at or greater than 1,320 gallons pursuant to CFR 40, §112.3, HSC §25270.
- On a farm, nursery, logging site, or construction site an SPCC is required for an AGT greater than 20,000 gallons and/or AGTs with cumulative storage greater than 100,000 gallons pursuant to State law, HSC §25270.

More information:

- Cal-EPA AGT information <http://www.calepa.ca.gov/CUPA/Aboveground/>
- USEPA SPCC information <http://www.epa.gov/oem/content/spcc/>
- SPCC FAQs: <http://calcupa.net/civica/filebank/blobdload.asp?BlobID=3031>
- California Code of Regulations <http://ccr.oal.ca.gov/linkedslice/default.asp?SP=CCR-1000&Action=Welcome>
- California Health & Safety Code <http://www.leginfo.ca.gov>