

COUNTY OF SAN LUIS OBISPO DEPARTMENT OF PUBLIC WORKS

SUBSURFACE STORMWATER INJECTION REQUIREMENTS

Introduction

What are Class V Stormwater Injection Wells?

Are underground infiltration systems covered by this designation?

Why did the County update their policy on these structures?

Is the change in County policy due to new requirements?

What is the process associated with constructing and registering a new Class V System?

How much does it cost to register a Class V system?

What are the County's requirements associated with new Class V systems?

Contact Information

What are Class V Stormwater Injection Wells?

Several types and configurations of stormwater drainage and infiltration systems are designated as Class V Stormwater Injection wells by the United States Environmental Protection Agency (EPA). Regulated Class V stormwater systems include dry wells, bored wells, and subsurface distribution systems (such as Contech or Stormtech chambers). Class V systems must comply with federal Underground Injection Control (UIC) program requirements.

These systems may have a variety of designs and names, but are defined in the Federal UIC regulations (40 CFR 144.36) as: A bored, drilled, or driven shaft whose depth is greater than the largest surface dimension, or, dug hole whose depth is greater than the largest surface dimension, or, an improved sinkhole, or, a subsurface fluid distribution system.

Are underground infiltration systems covered by this designation?

Yes. Subsurface fluid distribution or infiltration systems (i.e. ADS, Stormtech, or Contech chambers) are included in the Class V Well designation.

Why did the County update their policy on these systems?

Recent changes to regional stormwater requirements have prompted an increase in the use of Class V wells to manage runoff volumes via enhanced infiltration. Apart from regional stormwater management requirements, these systems may also be installed to comply with the Public Improvement Standards. These County's requirements on Class V systems are to be incorporated into the scheduled 2019 Public Improvement Standards update.

There are no detailed State or Federal requirements for the design or approval of new Class V systems. However, the County is the local authority responsible for ensuring that new Class V wells do not endanger underground drinking water supplies. The County's requirements are intended to ensure that new systems

SUBSURFACE STORMWATER INJECTION REQUIREMENTS

meet the minimum requirements set forth by the EPA to and protect underground drinking water supplies. **Requirements are summarized on page 3 of this document.**

Is the change in County policy due to new requirements?

No. The Federal requirements that regulate stormwater discharges as Class V wells were most recently updated in 2003. The County changed the policies related to the review and approval of these systems to improve alignment with federal requirements.

What is the process associated with constructing and registering a new Class V system?

Applicants that submit drainage plans to the County for review will be notified of the need to register if the plans include a Class V system. The County will verify that the proposed design meets the requirements, (referenced on page 3) and request corrections if necessary. A condition for 'Public Works Inspection prior to Final' will be added to the building permit with notes that the applicant must submit evidence to Public Works they have registered their Class V system with the US EPA's Region 9 Office.

All Class V wells in California must be registered with US EPA's Region 9 Office. Registration of Class V Wells is completed by filling out an online form prior to commencement of use. *Completing registration while the system is still planned or under construction is strongly encouraged.*

The registration form can be found at: https://www.epa.gov/uic/forms/underground-injection-wells-registration

How much does it cost to register a Class V system?

There is no fee associated with registration, and there are no ongoing reporting requirements.

How does this relate to the County's construction permitting process?

The Public Works Department will continue to review drainage plans for new development in San Luis Obispo County.

Where can I find more information about Federal requirements for Class V Wells?

Introduction to Class V wells: https://www.epa.gov/uic/basic-information-about-class-v-injection-wells

Additional information about Federal regulations of stormwater discharges and Class V wells: https://www.epa.gov/sites/production/files/2015-08/documents/fs storm.pdf

A summary of federal requirements for Class V systems: https://www.epa.gov/uic/federal-requirements-class-v-wells

Additional information about Class V systems in California can be found at: http://www.waterboards.ca.gov/board reference/2014fall/docs/dry wells fs.pdf

What are the County's requirements associated with new Class V systems?

The County will review all development plans proposing subsurface stormwater infiltration systems (either drywells or chamber systems) based on the following criteria:

- 1. Not permitted on project sites with an elevated risk of releasing contaminants (spills), or on properties susceptible to receiving contaminates from adjacent land uses. This includes, but is not limited to:
 - a. Vehicle repair facilities or fueling stations,
 - b. Facilities that store, transfer or generate hazardous materials,
 - c. Autopart recycling facilities,
 - d. Sites with a history of spills or illegal dumping.
- 2. Must incorporate a stormwater pre-treatment device to remove solids and ensure that particulate debris is separated and removed from inflows.
- 3. Must include an operation and maintenance manual and schedule.
- 4. Applicant must submit soils report which includes:
 - a. Infiltration Rate

Infiltration (minutes/inch)	Min. distance to groundwater
<1	50 feet
1-4	20 feet
5-29	8 feet
30 up	5 feet

^{*}Infiltration Rate utilizing Central Coast Low Impact Development Initiative Native Soil Assessment for Small Infiltration-Based Stormwater Control Measures/County of San Luis Obispo Post Construction Handbook Appendix D, or approved alternative.

5. Setback requirements (minimum)[‡]:

Buildings or structures*	_10 feet	Reservoirs	200 feet
Property lines	10 feet	Water supply wells	100 feet
Domestic water line	_10 feet	Trees	10 feet
Water Main	25 feet	Stream, springs, ponds	100 feet

[‡] Refer to guidance of soils engineer.

- 6. Additional Dry Well Considerations:
 - a. Penetration: 10 feet minimum into permeable porous soils recommended
 - b. Dry well surface inlet: 3-inch minimum above bottom of retention basin (as applicable)
 - c. Natural ground slopes: 15% maximum recommended, not accepted on slopes greater than 25%.
 - d. Proximity to cut or natural slopes: As recommended by soils engineer
- 7. Additional Subsurface Chamber Considerations:
 - a. Must incorporate inspection and maintenance access ports, to be shown on plans.
 - b. Port covers must be clearly marked 'STORM'

^{*}Building or structure setbacks for drywells or infiltration chamber systems must conform to Section 1804 of the California Building Code.

SUBSURFACE STORMWATER INJECTION REQUIREMENTS

Contact Information

San Luis Obispo County Public Works Department

805-781-1596 <u>dgrim@co.slo.ca.us</u> *David Grim, Development Services*

805-781-5274 <u>jalambert@co.slo.ca.us</u> *Jeff Lambert, Development Services*

San Luis Obispo County Planning and Building Department

805-781-5602 <u>aschuetze@co.slo.ca.us</u>

Anthony Schuetze, Stormwater Program

Manager